

OFFICE OF THE DISTRICT LABORATORY

Public Health Engineering Department, SUB DN Neemuch, Distt. Neemuch(M.P.)

Annexure C

No. 07

Date: 08/01/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Khushvant Singh Rathore
Sub engineer
from P.H.E. Department, Neemuch(MP) inspected the Gyanodaya International School,
Village Kanawati, Teh. & Distt. Neemuch(MP) on 07/01/26 and on the basis
of Water Test Report(Attached) bearing No. 71
Dated 12/12/25 (PHED Lab) certified that the Gyanodaya International
School, has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school
building & the campus as per the norms prescribed by the Central/State/U.T Govt.

This certificate is valid till 6 month from date of issue.

Signature with Seal : [Signature]
Assistant Engineer
Public Health Engg. Sub Div.

Name : Kamlesh Pathak
NEEMUCH (M.P.)

Designation : Assistant engineer.

Name & Add. Of Department: Public

Health engineering department

To

The Principal

Gyanodaya International School

Kanawati, Neemuch(MP)

[Signature]
19/01/26
Principal
Gyanodaya International School,
Kanawati, Neemuch (M.P.)

District Water Testing Laboratory
Public Health Engineering Department (PHED)
Manasa Naka, Near Navgrih Shani Mandir Neemuch (M.P.)

Test Report

ULR No. TC 1 3 5 4 2 2 5 0 0 0 0 0 0 0 7 1 F

Condition of sample : OK or Not		Nature of sample: Drinking Water/ Other		Unique Identification Code.	82NMH	Sample Not Collected by Lab	
Sender's name and address: Principal Gyanodaya International School Kanawati Dist. Neemuch (M.P.)				Quantity of sample-	1 Liter	Nature of Packaging - Glass/PP	
				Date and Time of Sampling -	10/12/2025/11 AM	Sender's letter Date	
				Sender's letter no.	652	DWTLMNH receipt Date	
				DWTLMNH receipt No.	82	Date of analysis completed	
				Date of analysis started	12/12/2025		
S.no.	Block	Gram Panchayat	Village	Habitation	Location		Source
1	Neemuch	Neemuch	Neemuch	Neemuch	Gyanodaya International School Kanawati Dist. Neemuch (M.P.)		R. O.(well)

Discipline : Chemical, Group : Water

Details of parameters, their test methods, units and specifications as per BIS

S.No.	Characteristics	Test Method	Unit	As per BIS - 10500:2012 & Amendment Jan 2021 For Drinking water		Test Result
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Sources	
						Sample Number
						1
						7
1	2	3	4	5	6	74
1	Total Hardness as CaCO ₃	IS 3025 (P-21):2009 RA 2023	mg/L	200	600	14.4
2	Calcium as Ca	IS 3025 (P-40):2024 No RA	mg/L	75	200	9.1
3	Magnesium as Mg	IS 3025 (P-46):2023 No RA	mg/L	30	100	8
4	Total Alkalinity as CaCO ₃	IS 3025 (P-23):2023 No RA	mg/L	200	600	26
5	Chloride as Cl	IS 3025 (P-32):1988 RA 2019	mg/L	250	1000	1
6	Colour	IS 3025 (P-04) :2021 No RA	Hazen	5	15	0.5
7	Turbidity	IS 3025 (P-10) :2023 No RA	NTU	1.0	5.0	6.60
8	pH @25°C	IS 3025 (P-11) : 2022 No RA	pH scale	6.5 to 8.5	6.5 to 8.5	25.8
9	Sulphate as SO ₄	IS 3025 (P-24) : 2022 No RA	mg/L	200	400	127
10	Conductivity @25°C	IS 3025 (P-14) : 2013 RA 2023	µmhos/cm	-	-	84
11	Total Dissolve Solids @180°C	IS 3025 (P-16) :2023 No RA	mg/L	500	2000	Agreeable
12	Odour	IS 3025 (P-5) : 2018 RA 2022	-	Agreeable	Agreeable	Agreeable
13	Taste	IS 3025 (P-8) : 2023 No RA	-	Agreeable	Agreeable	Agreeable
14	Fluoride as F-	IS 3025 (P-60) : 2023 No RA	mg/L	1.0	1.5	0.06

Specific information :

- This report shall not be produced partly or full without written Permission of laboratory.
- Samples will be stored for a period of 05 days from the date of issue of report.
- This laboratory does not hold any responsibility for variation in results for samples kept on hold.
- Results relate only to the items tested and the sample as Received.
- Collection of sample from the source "This information is provided by the Customers only" and laboratory will not responsible for such information.

Technical Manager
District Water Testing Laboratory
Neemuch (M.P.)

End of Report
Page 1 of 1

Reviewed By
Pooja Malviya
Quality Manager
Authorized Signatory
District Water Testing Laboratory Neemuch(M.P.)
Neemuch (M.P.)

/DWTL/PHED/NMH/ /2025 Issue Date:

Principal
Gyanodaya International School,
Kanawati, Neemuch (M.P.)

District Water Testing Laboratory
Public Health Engineering Department PHED
Manasa Naka, Near Navgrih Shani Mandir Neemuch (M.P.)

Sender's Letter No.:652 Date: 10/12/2025		DWTL Receipt No. 82		DWTL Receipt Date: 10/12/2025		Unique Identification Code. 82/NMH	
Physical and Chemical Test Report with details of Parameters, their Test methods, Units and Specifications as per BIS							
S.No	Characteristics	Test Method	Unit	As per BIS -10500:2012 & Amendment Jan 2021 For Drinking water		Test Results	
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Sources	Sample Numbers	
						1	
15	Nitrate as No ₃	PDA Method, Based on std. Method 1960& NEERI Manual 2012	Mg/l	45	45	0.13	
16	Iron as Fe	IS 3025 (P-53) : 2024 No RA	Mg/l	1.0	1.0	0.05	
17	Manganese as Mn	IS 3025 (P-59) : 2023 No RA	Mg/l	0.1	0.3	0.00	
18	Arsenic	By Kit	Mg/l	0.01	0.01	0.00	
19	Residual Chlorine as Cl ₂	By Visual/ Comparative method	Mg/l	0.2	1.00	0.0	
Bacteriological Test Report With Details of their Test Methods, Units and Specifications as per BIS							
S.No	Characteristics	Test Method	Unit	As per BIS -10500:2012 & Amendment Jan 2021 For Drinking water		Test Results	
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Sources	Sample Numbers	
						1	
						0	
1	Total Coliform	APHA 23 rd Edition	Per 100ml	NIL		0	
2	Faecal Coliform(TTC)	APHA 23 rd Edition	Per 100ml	NIL		0	

Remarks (if Any)-

[Signature]
Technical Manager
District Water Testing Laboratory
Neemuch (M.P.)

[Signature]
Pooja Malviya
Quality Manager
Authorized Signatory
District Water Testing Laboratory Neemuch(M.P.)

[Signature]
Principal
Gyanodaya International School
Kanawati, Neemuch (M.P.)
Issue no. 71 /DWTL/PHED/NMH/ /2025 Issue Date: